

Release Notes

Belimo Energy Valve™ Software Version 3.1.3

Date: February 21st, 2020

With this update you are able to disable the BACnet Read Property Multiple service (Data sharing – Read-PropertyMultiple-B (DS-RPM-B) on the Belimo Energy Valve in order to protect it better from a communication overload and therefore communication interruptions.

+

BACnet MP and Modbus settings

- Overview
- Data
- Status
- Settings
- Application
- Date & time
- Users
- IP
- BACnet/MP/Modbus**
- Cloud settings
- Maintenance

Communication protocol

BACnet IP
 BACnet MS/TP
 MP
 Modbus TCP
 Modbus RTU
 None

BACnet MS/TP settings

38400 Baudrate
3 MS/TP address
127 Max master
 120 Ohm termination

Device object settings

1000 Instance ID
EV3.1.3 Device name
Energy Valve Device description
PM EU Location
 Allow ReadPropertyMultiple Access ⓘ
0 System status
1 Protocol version
12 Protocol revision

Submit